

WATER RELIEF -or- STEAM RELIEF installation recommendation for BOILERS

Capacity and pressure of relief to be determined by label plate data on boiler

- Safety Valve shall be piped in vertical position as shown.

INLET PIPING

- Safety valve inlet and inlet piping shall be equal in diameter.
- Safety valve inlet and inlet piping diameters shall be equal or smaller than the opening or port to which it is attached.

